

Portable Appliance Test Certification

Is hereby granted to: -

CATOR HALL

Portable Appliance Testing carried out using BS approved test equipment.
Equipment used during test – PRIMETEST 100 appliance tester
-MILD 100 Microwave Leakage Detector

Dated – 10th MAY 2024

Approved by - DANIEL EMMONDS

Issued in accordance with The Management of Health & Safety at Work Regulations 1999

Portable Appliance Testing

Address: CATOR HALL, EAKRING. NG22 0DA

10th MAY 2024

No.	Description	Location	Status
1	WATER BOILER	KITCHEN	PASS
2	KETTLE BASE		PASS
3	KETTLE		PASS
4	KETTLE BASE		PASS
5	KETTLE		PASS
6	PRINTER LEAD	MEETING ROOM	PASS
7	PRINTER LEAD		PASS
8	WIFI		PASS
9	EXTENSION LEAD		PASS
10	HOT CUPBOARD	STORES	PASS
11	AIRCON UNIT		PASS
12	AIRCON UNIT		PASS
13	AIRCON UNIT		PASS

Firecrest uk
fire and safety services

Fire Alarm Systems, Emergency Lighting, Fire Extinguishers,
Fire Risk Assessments, Fire & Safety Signs, PAT Testing

Unit 4 Beacon Court
New Ollerton
Newark
Notts
NG22 9QL
Tel: 01623 861 331
Fax: 01623 861 222
www.firecrestuk.co.uk

Portable Appliance Test Report

For

**Cator Hall
Kirklington Road
Eakring
Notts
NG22 0DA**

10th May 2024

Tested By

Daniel Emmonds

Portable Appliance Testing

Code of Practice & Certification

Electricity at work act 1990

Registration, Inspection & Testing of Portable Electrical Equipment

This Code of Practice is based on the need to test and record the results of all portable electrical equipment.

The information contained here in is taken from guidelines given by the Health & Safety Executive & those which have been proven with local businesses.

The Law Requires

The Health & Safety at Work Act was extended in 1989 to include the safety of all electrical appliances in the workplace. The Regulations were passed as law in April 1990 & was known as **The Electricity at Work Regs 1989**.

Every Business & Workplace are now required by law to be totally responsible for the safety of their Portable Electrical Appliances.

As with all Laws ignorance is no excuse, it is your sole responsibility to ensure all appliances within your business meet these specific requirements.

What are the requirements & how can they be met

1. What is a Portable Appliance?

It is any kind of electrical equipment which derives its power via a flexible cable & a plug. They may be 415 volts or below irrespective of age.

Typical Examples are Floor Cleaners, Kettles, Heaters, Fans, Televisions, Table Lamps, Photocopiers & Computers.

2. Testing Equipment

Using Proven Testing Equipment each appliance will be tested for earth bond & insulation. For double insulated equipment a flash test will also be carried out as necessary.

All power cables will be visually checked, plugs and fuses will be checked.

All plugs will be checked for
Correct Fuse Rating

Damage
Insulated Pins
Correct use of Cord Grip

A label will be put onto each appliance stating the Test Date, Retest Date & its own Number.

3. **Recording Test Results**

All the test results will be logged on sheets with the location & number and a copy sent to the customer.

4. **Locating & Testing Equipment**

All appliances on the property must be checked, including those owned by members of staff. In order to do this, we need your co-operation in giving access to all rooms, cupboards etc - even if there are no appliances in them.

5. **Faulty / Damaged Appliances**

Any appliances found faulty will be marked with a failure label and reported to a member of staff and must not be used. It will be indicated as failed on the report.

Certification

All our work will be carried out to the latest standards in Portable Appliance Testing, and Microwave Leakage Testing, using Approved equipment.

FIRECREST UK LTD cannot accept any responsibility for further degradation of appliances due to incorrect usage or otherwise. The test results are designed in the long run to highlight potential dangers in appliances before they occur, it cannot therefore be regarded as evidence of condition of the item tested at any other time.

The information contained within this document was correct at the time of testing.

FIRECREST UK LTD
Unit 4 Beacon Court
New Ollerton
Newark
Notts
NG22 9QL

Tel: 01623 861 331
Fax: 01623 861 222
Web: www.firecrestuk.co.uk
Email: sales@firecrestuk.co.uk